



44	1 EA	36IRB	SALAMANDER	
30 MBTU	0.75		78 AFF	
47	1 EA	36S-6B	RANGE	
215 MBTU	0.75		32 AFF	
60	1 EA	VICM48	CHEESE MELTER	WALL MOUNT
40 MBTU	0.75		78 AFF	
65	1 EA	V2B18	RANGE	
70 MBTU	1.25		32 AFF	
66	1 EA	V2B18	RANGE	
70 MBTU	1.25		32 AFF	
67	1 EA	V2B18	RANGE	
70 MBTU	1.25		32 AFF	
68	1 EA	36R-36CB	CHARBROILER	REF BASE
96 MBTU	0.75		32 AFF	
120 (1)	6.7A		5-15	
70	1 EA	MSA72	GRIDDLE	
162 MBTU	0.75		32 AFF	
71	1 EA	VICM72	CHEESE MELTER	WALL MOUNT
60 MBTU	0.75		78 AFF	

GENERAL NOTES - PLEASE READ

VENTILATION:
ALL COOKING EQUIPMENT MUST BE VENTILATED BY AN APPROVED APPLIANCE IN ACCORDANCE WITH ALL APPLICABLE CODES.

FIRE SUPPRESSION:
ALL COOKING EQUIPMENT MUST BE PROTECTED BY AN APPROVED FIRE SUPPRESSION SYSTEM IN ACCORDANCE WITH ALL APPLICABLE CODES.

CONNECTIONS:
ALL PIPING, FITTINGS, AND INTERCONNECTION SERVICES SHOWN ARE TO BE SUPPLIED AND INSTALLED BY LICENSED CONTRACTORS IN ACCORDANCE WITH ALL LOCAL CODES.

GAS CONNECTIONS:
EXTERNAL GAS REGULATORS, FLEXIBLE GAS LINES AND RESTRAINING CABLES PROVIDED WITH THE EQUIPMENT MUST BE INSTALLED BY LICENSED CONTRACTORS IN ACCORDANCE WITH ALL LOCAL CODES. INCOMING GAS MANIFOLD SUPPLY PRESSURE MUST NOT EXCEED 0.5 PSI (4" W.C.)

BY OTHERS:
VERIFY ALL EQUIPMENT LISTED AS BY OTHERS FOR SIZE AND MECHANICAL SERVICE REQUIREMENTS.

NOTE:
IN LINE WITH THE POLICY TO CONTINUALLY IMPROVE ITS PRODUCTS, THE MANUFACTURERS RESERVE THE RIGHT TO CHANGE MATERIALS AND SPECIFICATIONS WITHOUT NOTICE.

01-05-2022
01-06-2022 : 11:05:50a
01-06-2022 : 01:44:19p
01-06-2022 : 01:56:18p

●	CONNECTION POINT
○	COLD WATER
○	HOT WATER
○	HOT + COLD WATER
○	DRAIN
○	POWER
○	SWITCH
○	CORD SET
○	CONV OUTLET RECP
○	DUPLEX RECP/TACLE
○	SINGLE RECP/TACLE
○	GAS
○	STEAM SUPPLY
○	STEAM RETURN
○	STEAM TAKE OFF
○	EXHAUST VENT
○	SUPPLY VENT
○	REFRIGERATION

PROJECT CODE
FENTN

VULCAN
THE VULCAN HART COMPANY
BALTIMORE, MARYLAND
410-284-0660

FENTON LIVE NC

REVISIONS	By	Date	Revision
	ddb	01-08-2022	LARGE FORMAT

NEXT STEP DESIGN
913 WEST ST.
ANNAPOLIS, MD 21401

SCALE:
AS NOTED
DATE: 01-08-2022
DRAWN BY: DDB
VH-FENTN