



GAS CONNECTION #: 1
LOCATED IN ITEM: 49
PIPE SIZE: 1.25 NPT
CP HEIGHT: 32" AFF
TOTAL GAS LOAD: 290 MBTU
INCLUDES ITEMS: 50 49
NOTE:

46	1 EA	VCBB36S	CHARBROILER
149	MBTU	1.25	32 AFF
49	1 EA	V6B36S	RANGE
260	MBTU	1.25	32 AFF
50	1 EA	VICM36	CHEESE METLER FLUE MOUNT
30	MBTU	0.75	MANIFOLD INTERPLUMB
51	1 EA	VCGG36	GRIDDLE COUNTERTOP
90	MBTU	0.75	30 AFF
120 (1)	2.0A	5-15	
52	1 EA	ARS36	REFRIGERATED BASE
120 (1)	6.7A	5-15	

GENERAL NOTES - PLEASE READ

VENTILATION:
ALL COOKING EQUIPMENT MUST BE VENTILATED BY AN APPROVED APPLIANCE IN ACCORDANCE WITH ALL APPLICABLE CODES.

FIRE SUPPRESSION:
ALL COOKING EQUIPMENT MUST BE PROTECTED BY AN APPROVED FIRE SUPPRESSION SYSTEM IN ACCORDANCE WITH ALL APPLICABLE CODES.

CONNECTIONS:
ALL PIPING, FITTINGS, AND INTERCONNECTION SERVICES SHOWN ARE TO BE SUPPLIED AND INSTALLED BY LICENSED CONTRACTORS IN ACCORDANCE WITH ALL LOCAL CODES.

GAS CONNECTIONS:
EXTERNAL GAS REGULATORS, FLEXIBLE GAS LINES AND RESTRAINING CABLES PROVIDED WITH THE EQUIPMENT MUST BE INSTALLED BY LICENSED CONTRACTORS IN ACCORDANCE WITH ALL LOCAL CODES. INCOMING GAS MANIFOLD SUPPLY PRESSURE MUST NOT EXCEED 0.5 PSI (4" W.C.)

BY OTHERS:
VERIFY ALL EQUIPMENT LISTED AS BY OTHERS FOR SIZE AND MECHANICAL SERVICE REQUIREMENTS.

NOTE:
IN LINE WITH THE POLICY TO CONTINUALLY IMPROVE ITS PRODUCTS, THE MANUFACTURERS RESERVE THE RIGHT TO CHANGE MATERIALS AND SPECIFICATIONS WITHOUT NOTICE.

●	CONNECTION POINT
○	COLD WATER
○	HOT WATER
○	HOT + COLD WATER
○	DRAIN
○	POWER
○	SWITCH
○	CORD SET
○	CONV OUTLET RECP
○	DUPLEX RECP/TALE
○	SINGLE RECP/TALE
○	GAS
○	STEAM SUPPLY
○	STEAM RETURN
○	STEAM TAKE OFF
○	EXHAUST VENT
○	SUPPLY VENT
○	REFRIGERATION

08-04-2021

PROJECT CODE
LGAIT

VULCAN
THE VULCAN HART COMPANY
BALTIMORE, MARYLAND
410-284-0660

LA GAURDIA
ITALINA
OGT LGA

REVISIONS

No.	Date	By	Revision
2	08/04/2021	ddb	LARGE FORMAT
4	08/18/2021	ddb	Item 51 Gas Size
5	10/06/2021	ddb	SUBMITTALS

POSTERNAK BAUER
479 WHITE PLANS ROAD
EAST CHESTER, NY 10709

SCALE:
AS NOTED
DATE: 10/06/2021
DRAWN BY: DDB
VH-LGAIT

1
OF 1